

One Hundred Seventh Legislature - First Session - 2021

Introducer's Statement of Intent

LB573

Chairperson: Senator Bruce Bostelman

Committee: Natural Resources

Date of Hearing: February 10, 2021

LB 573 clarifies that the 25 kilowatt limit on a qualified facility is measured in alternating current. This clarification harmonizes the rating of a qualified facility with that of electrical grid measurements, brings provisions in line with changes in LB 76 (2019) made in Chapter 77, and would ensure consistent application across all utilities.

The following constitutes the reasons for this bill and the purposes which are sought to be accomplished thereby:

Principal Introducer: _____

Senator Eliot Bostar