

finish with my time, then I'd appreciate it.

SENATOR MOORE: Well, I am just going to read directly from this to make sure that it's, I'm reading from some of this Public Record. And to begin with, the building opened October 11, 1976. Well then in a list of problems of the building that the university gave to the contractor on September 27, 1977, it reads, the punch list dated September 27, 1977, refers to several instances of the brick cracking in the south wall, a missing mortar joint on the east wall, bricks broken out on the north side and cracking of brick on the west end of the atrium, and it lists all these things out and then it said, they looked at it and then they came back and the architectural firm, who was sued, Wilscam, reported the results of the investigation to Mr. Money (phonetic), Frederick Fast reported to Mr. Money what the...recommended only that the cracks be patched or caulked to prevent further damage to the walls. Money directed to Wilscam to have the general contractor examine and repair the cracks. Although (inaudible) to the general contractor caulked some of the more accessible cracks, those which did not require scaffolding, it did not complete the building repairs noted in the punch list. So right there they agreed to do something, but they never did anything more that would have taken scaffolding to do it. They left the big cracks there, never caulked them, never did anything to them. Well during 1978, however, it became apparent that the general contractor would not repair the cracks and Yarbrough (phonetic) who worked for the university, Mr. Yarbrough's department gradually assumed full responsibility for patching the cracks in the College of Pharmacy building. Mr. Yarbrough testified, this is in court, that these cracks lengthened, widened and increased in number to such an extent that the building required caulking quarterly or semiannually over a five-year period from 1978 to 1982.

PRESIDENT: One minute.

SENATOR MOORE: And neither...by 1982 neither the general contractor nor the university had caulked any of the cracks that required scaffolding. So...and it's going to take me a while to go through this and I think I'll do it more at a later time, but I encourage you to read over that and I will go through this in more detail at a later time.

PRESIDENT: Senator Smith, please.